

Chilled Water Problems

- 1) Building chilled water system used for heat exchange of chillers
- 2) Symptom: SVX chiller cannot hold temperature set point (especially during hot summers)
- 3) CV-5 regulates flow of chilled water for everything after Silicon chiller and SUVA, can be closed to 30% to direct more flow to the Silicon chillers
- 4) Possible cause of low flow: clogged strainer

Coordinate with the Silicon SPLs